

Corrigendum no.2 issued based on Pre-Bid Conference discussion held on May 25, 2015 at Sir MV Conference room Simrol campus IIT Indore.

The following Contractors attended the meeting:-

- 1) M/s Simplex Infrastructure Limited (Mr. Susen Devri & Mr. N.K. Yadav)
- 2) M/s PREMCO Rail Engineers Limited. (Mr. Sushil Kumar)
- 3) M/s United Project Construction Ltd. (Mr. Hemant Gupta)
- 4) M/s N. H. Brothers. (Mr. Ahsaan)

All queries were discussed and clarified during the pre-bid conference on 25/05/2015 and following corrigendum is issued.

Table I

S.No.	Queries raised	Clarification/Decision
1	Mr. Susen Devri from M/s Simplex has raised the issue of restriction of working days/hours mentioned in clause no. 21 of NIT.	No change in the provision of clause no.21 of NIT.
2	Mr. Susen Devri from M/s Simplex suggested further break up for tiling work under point no. 10 of mile stone and payment schedule.	The mile stone for the payment of the point no. 10 i.e. for tiling work is further subdivided as below: Ground floor : 1.5% First Floor : 3% Second Floor : 3% Stair case including approach, all cills, bands, platform and all other similar miscellaneous works: 1% 8.5%
3	Mr. Hemant Gupta from M/s UPCL raised the issue of non supply of electricity. He expressed concern of requirement of running 24 hours generator.	Only single phase power will be provided for small usage.
4	Mr. Hemant Gupta from M/s UPCL wanted clarification on scope of work for electrical fittings and fixtures, fans, light AC etc.	As per tender condition.
5	All contractors suggested for make the site meeting fortnightly.	There will be weekly meeting instead of bi-weekly meeting. However the meeting date may be rescheduled with the permission of the Engineer In-charge. All the meeting must be attended by all the service providers concerned with the work progressing at

		that stage. The decision of Engineer In-charge in this regard i.e. the service provider those who need to be present will be final.
--	--	---

In addition to above clarification, Executive Engineer (Electrical) cleared following points:

1. Main electrical panel should be type tested to the satisfaction of EE (Electrical).
2. Design calculation and sizing of chilled water piping, power cabling, and electrical load should be presented or submitted at the time of presentation.
3. Lux level calculation of lighting fixtures should also be submitted by the contractor at the time of presentation.

*Q. Hassan
28/5/2015
Supdt. Engineer.*