



Ref. No.: IITI(MM)/HoR/1/1A/305/AK/2022-23/2

Sep 26, 2022

PREBID REPORT

The offline meeting for Pre-bid discussion and presentation was held at Central Dining Hall, IIT Indore on Sep 15, 2022 @ 03.00 P.M. for Supply, Installation and Testing of Kitchen Ventilation System through GeM Custom Bidding, Bid No. GEM/2022/B/2521033.

The report of the meeting is as below:

Sl. No.	Query raised by firms	Reference Document	Query/Clarification/Deviation Sought	Response from IITI
01	M/s Supreme Engineering Services, Indore	GeM tender Technical Specifications	All burners should be fixed at location	Burner location will be fixed during execution of work, As the kitchen is in operational condition.
02	M/s Supreme Engineering Services, Indore	GeM tender Technical Specifications	Single air washer/ scrubber is not convenient for both kitchens. that should be two of 9000 CFM.	The system will be designed for single kitchen only.
03	M/s Supreme Engineering Services, Indore	GeM tender Terms & Conditions	The Hood size is also short, size needs to be amended accordingly to 12'x4'x1 6'.	The system will be designed for single kitchen only.
04	M/s Supreme Engineering Services, Indore	GeM tender Terms & Conditions	Required proper suction area for fresh air.	The outside area of kitchen is positively pressurized.
05	Ananjay Softek Solutions Pvt. Ltd.	GeM tender Terms & Conditions	i)10000CFM DIDW type exhaust unit with dry scrubber unit -35mm static pressure. ii)Along with the scrubber arrangement. iii)Fire resistance canvas connection. iv)G i Mounting frame v)Vibration mounts/Spring suspenders for floor mounted unit. vi)Filter with necessary frame if necessary. vii)Drive assembly and motor. viii)Starter panel power cabling and earthing. With all necessary arrangements. Proposed Deviation :- 8000 CFM*2= 16000 CFM	No Deviation

सहायक कुलसचिव
(सामग्री प्रबंधन विभाग)
Assistant Registrar
(Materials Management Section)

06	Ananjay Softek Solutions Pvt. Ltd.	GeM tender Terms & Conditions	SS HOOD : i) Supply, installation, testing & commissioning of SS Hood with baffle filter and grease/oil removal arrangements. ii) Size (7'x4'x1.6")ft. iii) Necessary vcd(Volume Control Damper). With all necessary arrangements. Proposed Deviation -6.5'X2.5'X1.6" (1) 4'X2.5'X1.6" (1) 2'X2.5'X1.6" (2) 6'X2.5'X1.6" (1) 7'X2.5'X1.6" (1) 5'X2.5'X1.6" (1) 2'X2.5'X1.6" (1) 6'X2.5'X1.6" (1)	No Deviation
07	Ananjay Softek Solutions Pvt. Ltd.	GeM tender Terms & Conditions	Air Distribution: Supply, installation, testing & commissioning of rectangular ducting complete in all respects.S.S. i) 22 Gauge ii) 24 Gauge Proposed Deviation SS sheet 22 gauge ,400X2= 800 SS Sheet 24 gauge ,350X2= 700	No Deviation
08	Ananjay Softek Solutions Pvt. Ltd.	GeM tender Terms & Conditions	VCD for Ducts Proposed Deviation -30 Sqft	No Deviation
09	Ananjay Softek Solutions Pvt. Ltd.	GeM tender Terms & Conditions	MS stand for FAN : i) Supply and Fabrication and Installation of MS stand, for resting ablow exhaust fan Proposed Deviation- Weight 350 kg	No Deviation
10	Ananjay Softek Solutions Pvt. Ltd.	GeM tender Terms & Conditions	Power cabling for exhaust fan. i) Size 3Cx4sqmm armored cable. Proposed Deviation -100x2 Mtr	No Deviation
11	Ananjay Softek Solutions Pvt. Ltd.	GeM tender Terms & Conditions	Minor Civil work: Wall Breaking and packing for Ducts Proposed Deviation- 30x2 Sqft	No Deviation

Note:-

1. The date of submission of online bids is extended upto 04/10/2022 @ 15:00 Hrs
2. The date of Opening of bids is extended upto 04/10/2022 @ 15:30 Hrs
3. The layout/drawing of operational kitchen as per Annexure-I (enclosed).
4. All prospective/willing bidders are requested to take note of this report as part of the Tender document. All other parts of the tender including the terms and conditions of the tender will remain Unchanged.

26/9/2022
Assistant Registrar
MM Section
IIT INDORE

सहायक कुलसचिव
(सामग्री प्रबंधन विभाग)
Assistant Registrar
(Materials Management Section)

