



भारतीय प्रौद्योगिकी संस्थान इन्दौर  
खण्डवा रोड़, सिमरोल, इन्दौर - 453 552, भारत  
**Indian Institute of Technology Indore**  
Khandwa Road, Simrol, Indore - 453 552, India

www.iiti.ac.in

IIT Indore

No.: IITI(MM)/MA/3/3A/169(PRJ)/JTV/20-21

July 03, 2021

### PREBID REPORT

Pre-Bid Meeting held through Video Conferencing at IIT Indore on June 28, 2021 at 11:30 Hrs (IST) regarding Tender ID No. 2021\_IITI\_635157\_1 dated June 24 ,2021 for Notice Inviting E-Tender “**Supply and Installation of Desktop, Printer UPS and Workstation**”

‘01’ firm have attended the Virtual Pre-Bid Meeting. However, online Pre-Bid queries from M/s. Samyak Computer, Indore has received through email. The clarifications and suggestions made sought form the respective department.

The details of the deliberation are attached as annexure ‘I’.

Sd/-  
Administrative Officer (MM)



Sl. No.	Reference of the Clause/ Page No. of the Tender Document	Query raised by	Response from IITI
<b>M/s. Samayak Computer, Indore</b>			
1	Technical Specification of Desktop at Pg. 25	Core i7 10700 comes with 2.9 GHz. This can be checked on Intel Website. Please change the same to 2.9 GHz	Accepted. Please read as 2.9 GHZ in place of 3.0 GHZ.
		Please add VPRO technology as this will improve processor frequency and bring security features.	Accepted in view of enhance the performance, hardware-based security, remote manageability etc.
		DIMM slots – 4 Nos. please change the same to 2 Nos as 4 Nos are OEM specific.	No changes.
		Please remove the below certifications as these are non-standard i.e.- CEL - WEEE, Japan Energy Law, South Korea E-standby, South Korea Ecolabel,	No changes.
		Monitor 21.5 Full HD Display.	All Bidders are requested to Quote as per mentioned Specification in tender document. Furthermore, bidder is also advised to quote separately FULL HD Display Price in BOQ Sheet No. 2
		2 Internal, 1 External Bay, Expansion slots 1 PCI Express V3.0 X1, 1PC Express V3.0 X16 M.2	Accepted. All bidders are requested to please read as additional specification in desktop category.
2.	Technical Specification of UPS at Page No.28	<p>Input facility -Phases / Wires: 1 Phase IN&amp; 1 Phase Out, Provision for 3 In or 1 In shall be provided with Output as Single Phase only.</p> <p>Technology and Capability:</p> <p>A) Microprocessor /DSP based control using IGBT devices and high switching frequency PWM (&gt;10kHz)</p> <p>a) Active Power Factor Correction</p> <p>b) (APFC) in converter to improve Input Power Factor &gt; 0.98</p> <p>B) True Online configuration with double conversion VFI SS 111</p> <p>Air Filters: UPS should have internal anticorrosion air filters for dust filtration.</p>	No Changes.



		Charging Current: 13 Amps	
		<p>Product Certificates: OEM should have own centralized Help Desk (24 X 7 support) with Toll-Free Number.</p> <p>Standards: BIS Approved, Rohs Compliant, ISO 9001, ISO 14001</p> <p>OEM Presence in India: The OEM shall be present in India for a minimum of 10 Years with an Overall UPS business of &gt; 400 Cr in India from last 3 years consistently.</p> <p>Overall Efficiency (AC to AC) – Online (Double Conversion): &gt;= 90% at Full Load &amp; &gt;= 98% in Green ECO mode</p> <p>PCB Manufacturing: PCB manufactured In OEM Factory in India</p>	<p>Note: Bidder are advised to quote for UPS as per mentioned specifications in the Tender Document at Pg.No 28.</p> <p><b>Furthermore, Overall Efficiency (AC to AC) Online (Double Conversion):</b> &gt;= 90% at Full Load &amp; &gt;= 98% in Green <b>ECO mode, treat as additional specification of UPS.</b></p>
3.	Technical Specification of Workstation at Page No.	1000W chassis or higher Performance advisor software for fine tune our workstations with a single click,	Point No. 02 accepted for additional feature of workstation category.

**Note:**

- 1) All desktops should have in-built Wi-Fi features.
- 2) It is advised to firm the quoted items should have strong escalation services. If any complaint, it shall be resolved within 24 Hrs from the date of escalation.
- 3) Bidders can participate in one or more items. Contract/Purchase order will be awarded to lowest bidder (L1) item wise/ In case of a package offer, Institute reserves the right to award contracts by comparing item wise and package offer, whichever is beneficial to the Institute.

**Note:** If any bidder wants to quote for UPS(Sl. no. 3) category only, then the quote shall be treated as along with Battery (Sl no. 4)and Rack (Sl no. 5).

**Last Date & Time of submission of bid is extended upto: 19<sup>th</sup> July 2021.**

**Date & Time of Opening of Technical bid: 20<sup>th</sup> July 2021.**

All prospective/willing bidders are requested to take note of this report as part of the tender document

All other parts of the tender including the terms and conditions of the tender will remain unchanged.

